

3562.** RING TERMINALS · WITH INSULATION SUPPORT



Specification 14 mm Plate

Ø (mm) 8,5

Din 46225

Wire size mm² (AWG) 2,5-6 (14-10)

Ø Insulation (mm) 3,8-5

Materials, temperature and contact resistance

Part nr.	Material	Finishing	Max. Temp. (°C)
3562.00	Brass	Natural	110
3562.02	Brass	Tin plated	120
3562.30	Bronze	Natural	120
3562.32	Bronze	Tin plated	130

Material thickness (mm) 0,8


Max. rated current

Wire section	3562.00 / 02 / 30 / 32
2.50 mm ²	20A
4.00 mm ²	26A
6.00 mm ²	34A

Application tool MN3560

Wire strip length 5.5 (±0.5) mm

Crimping parameters & pull out force

Wire section (±10%)	Conductor 		Insulator	Pull-out force (N)
	Height (mm)	Width (mm)	Width (mm)	
2.50 mm ²	2.85 (±0.05)	5.20 (±0.05)	6.48 (±0.10)	230N @ 60s
4.00 mm ²	3.25 (±0.05)	5.20 (±0.05)	6.52 (±0.10)	310N @ 60s
6.00 mm ²	3.45 (±0.05)	5.24 (±0.05)	6.53 (±0.10)	360N @ 60s

Values only valid for the application tool specified upwards. The insulator widths are only indicative as they are dependent on the sheath thickness of the wire used.

Winding number 2000

Approved regulations



Part nr.	Approval	Standard	File	Certified framework
3562.00	UL	UL 486A-486B	E232316	AWG 14-10 (41-105 Stranded Cu) / MN3562
3562.02	UL	UL 486A-486B	E232316	AWG 14-10 (41-105 Stranded Cu) / MN3562

Approvals



3562.**
RING TERMINALS · WITH INSULATION SUPPORT


Drawing


Disclaimer

Data obtained from Escubedo Laboratory essays, using own methodology, cablings, equipment and original crimping tools, done in laboratory conditions and following the indicated standards, errors and omissions excepted. This document has no contractual meaning and it is publicised only for informative purposes. It can be changed without prior notice. The end customer has the sole responsibility to check these characteristics in its environment and with its own components, manufacturing methods and equipment. See also the full range product overview if available. For further information please visit our web site or contact us

Rev. Nr.	Concept	Date	Created/Revised	Approved
A3	Change company name and logo	2021-10-21	Laboratory Dept.	E. Roura
A2	Update rated current	2018-11-28	Laboratory Dept.	E. Roura
A1	Datasheet generated automatically [A1]	2018-10-01	Laboratory Dept.	E. Roura

Escubedo Connection Systems, S.A.U. · Ctra. de Girona-Olot Km. 35,5 · 17843 Riudellots de la Creu · Girona · Spain
 Tel.: 34 972 171 706 · Fax: +34 972 171 714 · info@escubedo.com · www.escubedo.com