



8441.**

6.3 (.250) TYPE SERIES · RECEPTACLES FOR CONNECTOR



Specification 6.3 mm Timer terminals

Wire size mm² (AWG) 0,5-1,5 (20-16)

Ø Insulation (mm) 1,8-3,3

Materials, temperature and contact resistance

Part nr.	Material	Finishing	Max. Temp. (°C)
8441.00	Brass	Natural	110
8441.01	Brass	Pre-tin-plated	120
8441.30	Bronze	Natural	120
8441.31	Bronze	Pre-tin-plated	130

Material thickness (mm) 0,32

Max. rated current

Wire section	8441.00 / 01 / 30 / 31
0.50 mm ²	4A
0.75 mm ²	6A
1.00 mm ²	8A
1.50 mm ²	10A

Application tool MN8441

Wire strip length 3.8 (±0.3) mm

Crimping parameters & pull out force

Wire section (±10%)	Conductor		Insulator	Pull-out force (N)
	Height (mm)	Width (mm)		
0.50 mm ²	1.30 (±0.03)	2.33 (±0.05)	3.53 (±0.10)	56N @ 60s
0.75 mm ²	1.35 (±0.05)	2.34 (±0.05)	3.53 (±0.10)	84N @ 60s
1.00 mm ²	1.40 (±0.05)	2.35 (±0.05)	3.55 (±0.10)	108N @ 60s
1.50 mm ²	1.45 (±0.05)	2.36 (±0.05)	3.55 (±0.10)	150N @ 60s




Values only valid for the application tool specified upwards. The insulator widths are only indicative as they are dependent on the sheath thickness of the wire used.

Winding number 3500

Approvals



Drawing





8441.**

6.3 (.250) TYPE SERIES · RECEPTACLES FOR CONNECTOR



Disclaimer

Data obtained from Escubedo Laboratory essays, using own methodology, cablings, equipment and original crimping tools, done in laboratory conditions and following the indicated standards, errors and omissions excepted. This document has no contractual meaning and it is publicised only for informative purposes. It can be changed without prior notice. The end customer has the sole responsibility to check these characteristics in its environment and with its own components, manufacturing methods and equipment. See also the full range product overview if available. For further information please visit our web site or contact us

Rev. Nr.	Concept	Date	Created/Revised	Approved
A2	Update crimp specifications	2020-05-12	Laboratory Dept.	E. Roura
A1	Datasheet generated automatically [A1]	2018-10-04	Laboratory Dept.	E. Roura